

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

No.275/2025


Dated: 02/09/2025



It is certified that an inspection team headed by ABHISHEK KUMAR (Name of Officers with designation) from... EXECUTIVE ENGINEER WATER SUPPLY AND SANITATION (PHED)

Inspected the... LAV KUSH TALENT ACADEMY, SALUMBER, RAJASTHAN

(Name & Address of the school) on .....22/06/2025.....(date of inspection) and on the basis of Water Test Report (Attached) bearing no....523..... dated...30/06/2025..... Of OFFICE OF THE REGIONAL LABORATORY, UDAIPUR (PHED Lab) certified that the LAV KUSH TALENT ACADEMY ( Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till...01/09/2028

  
अधिशायी अभियता  
जन. स्वा. अभि. विभाग  
जिला सलुम्बर (राज.)

Signature with Seal:   
Name : .....  
Designation :   
Name & Address of the Office/Department: PHED (Salumber)

To  
LAV KUSH TALENT ACADEMY  
SLUMBER, RAJASTHAN  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies

**OFFICE OF THE SUPERINTENDING CHEMIST  
PUBLIC HEALTH ENGINEERING DEPARTMENT, REGIONAL LAB UDAIPUR  
REPORT OF THE CHEMICAL EXAMINATION OF WATER**

No. Lab/Tech(Chem)/2025-26/ 523

Date 30-6-2025

To,  
Principal  
LAV KUSH TALENT ACADEMY  
Salumber  
Soure-Filter Water

**Not Valid for Water  
Quality Legal Cases**

Ref:- Your Ref.No. 28 Dated 27/05/2025

Date Of Receipt :-27/06/2025

**The Sample was not  
Collected by this Laboratory**

Lab Sample No.				582
Source & Location		Desirable Limit as Per IS	Permissible Limit in absence of Alternate Source IS 10500:2012	Lav khush Talent Academy
Village/Town				Salumber
Date Of Collection		10500:2012	IS 10500:2012	27.06.2025
1	pH	6.5-8.5	6.5-8.5	7.8
2	Alkalinity Methyl Orange	200	600	240
3	Total Hardness	200	600	244
4	Chlorides as Cl	250	1000	60
5	Nitrate as NO <sub>3</sub>	45	45	20.7
6	Total Dissolved Solids	500	2000	580
7	Fluorides	1.0	1.5	0.87
8	Turbidity N.T.U.	1.0	5	0.5

Note:- All Results Except Sr.No. 1 & 8 are in mg/L.

  
 Superintending Chemist, 30/6  
 PHED Regional Lab. Udaipur